

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 1269

Dated:

It is certified that an inspection team headed by Sandeep Kumar

(Name of Officers with designation) from Junior Engineer PHED

inspected the SARASWATI G.V. CONVENT SCHOOL, BEENJH BAYALA

(Name & Address of the school) on 30/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated

of (PHED Lab) certified that the

SARASWATI G.V. CONVENT SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 29/05/27

Signature with Seal: (अमरजीत सिंह)

Name: सहायक अभियन्ता

Designation: जन स्वा. अभि. विभाग

Name & Address of the उपखण्ड पदमपुर-8296

To SARASWATI G.V. CONVENT SCHOOL

BEENJH BAYALA

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Bacteriological Examination of Water

Date : 24/04/2025

Sl. No. 114
24.4.2025


To,
Principal,
Saraswati G. V. Convent School,
Beenjhayala.

District : GANGANAGAR
Block : PADAMPUR
Sample Taker : Self

Reference No : 621-SGVCS-BBL-2025, Dated : 22/04/2025
Date of Receipt : 22/04/2025
Date of Exam : 22/04/2025

Sample No.	Date & Time of Collection	Gram Panchayat	Village / Town / City	Source Name	Location	Residual Chlorine (in mg/L)	Total Coli Form Organism (MPN per 100 ml)	Remark (As per T-Coli Form)	Remark (Water)
197	22/04/2025	BINJWALA	BINJH BAYALA	CWR	Tap water Cooler Diggi Ke Pass Saraswati G. V. Con	Nil	Nil	Satisfactory	Potable

Note : (1) Samples are not collected by laboratory.
No. Lab./Tech.(Bact)/2025-26/197
(2) Report is not valid for water quality legal purposes.


Junior Chemist
District Laboratory, Ganganagar
(प्रभा बंसल)
कनिष्ठ रसायनज्ञ
जन स्वा. अभि. विभाग
मिला-प्रयोगशाला, श्रीगंगानगर
डी.डी.ओ.कोड नं. : 10484



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Chemical Examination of Water

Sl. No. / 95
22/4/2025

To
Principal,
Saraswati G V Convent School,
Beehbayala Padampur.

Reference No : 621, Dated : 22/04/2025

Date of Receipt : 22/04/2025

District : GANGANAGAR
Block : PADAMPUR
Sample Taker : Your Self

Source	Permissible Value as per S.I.S. 10900/2012		Tap
Location			Water Cooler-Near Digpl. Saraswati G V Convent Sch
Other Habitation			BINJWALA
Village/Town			BINJH BAYALA
Gram Panchayat			BINJWALA
Date of Collection	Desirable Limit	Permissible limit in absence of alternate Source	22/04/2025
Date of Examination			22/04/2025
Sample No.			111

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.8
Turbidity(NTU)	1	5	0
Colour	5	15	Colourless
Odour	Agresable	Agresable	Smell less
Temperature	---	---	---
Total Alkalinity	200	500	110
Total Hardness (as CaCO ₃)	200	500	140
Calcium (as Ca)	75	200	15
Magnesium (as Mg)	30	100	24.4
Chloride(as Cl)	250	1000	20
Sulphate(as SO ₄)	200	400	---
Nitrate as(NO ₃)	45	45	3
Fluoride	1.0	1.5	0.29
Total Dissolved Solids	500	2000	270
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Note : (1) Samples are not
collected by laboratory.
(2) Report is not valid for
water quality legal purposes.

Remarks : Water is Potable (P)/Unpotable (U)
No.Lab./Tech.(chem)/2025-26/111

Junior Chemist
PHEO Laboratory, Ganganagar
(प्रमोद कुमार)
कर्मिक रसायनज्ञ
जन स्या. अभि. विभाग
जिला-प्रयोगशाला, श्रीमंगलनगर
डि.डी.ओ.कोड नं. : 10484